



# Chambersburg Fire Department

130 North Second Street • Chambersburg, PA 17201-1640  
Telephone: (717) 261-3230  
Fax: (717) 261-3296

## LP Gas Guidelines for Vendors

The following guidelines are in place as of June 25, 2002 for all vendors requiring an *Application for Temporary Health License to Operate a Food Vendors Stand*. In the event that a requirement is not met the stand will be ordered to cease all operations until the requirements are met.

1. Each "commercially built" food trailer shall have no more than two (2) DOT approved cylinders not to exceed 100 lbs. capacity in each cylinder. All others shall have no more than one (1) cylinder not to exceed 60 lbs. capacity. Cylinders out of test date will be ordered removed from service.
2. Each cylinder shall be stored in an upright position and secured. String, rope, or duct tape is not permitted.
3. Each vendor shall have no less than one (1) 20 B:C rated fire extinguisher.
4. Each fire extinguisher shall be inspected and tested in accordance with NFPA 10 guide for portable fire extinguishers.
5. A minimum separation distance of ten (10) feet or a distance acceptable to the authority having jurisdiction shall be maintained between the appliance and the cylinder.

Business Name \_\_\_\_\_  
Vendor Name \_\_\_\_\_  
Street Address \_\_\_\_\_  
City \_\_\_\_\_  
State \_\_\_\_\_ Zip \_\_\_\_\_  
Phone Number \_\_\_\_\_  
 ChambersFest     AppleFest     Other \_\_\_\_\_

I agree to comply with the above referenced requirements and further understand that non-compliance will result in an order to cease operations until the requirements have been met.

\_\_\_\_\_  
Signature of Vendor or Designee

\_\_\_\_\_  
Date